## COPPER CLEVIS HANGERS

**ANVIL INTERNATIONAL #CT65** 

## **COPPER TUBING HANGERS**



## Fig. CT-65

## Light Weight Adjustable Clevis

Size Range: 1/2" through 4"

Material: Carbon steel

**Finish:**  $\square$  Copper plated, also available in  $\square$  yellow dichromate and  $\square$  plastic coated.

Service: Recommended for suspension of non-insulated, stationary copper tube.

Approvals: Complies with Federal Specification WW-H-171-E (Type 12).


Installation:

(1) Adjustment may be made either before or after tubing is in place without temporary support of pipe.

(2) Hanger rod and nuts may be locked into position after adjustment by use of the upper nut.

**Features:** Provides for adjustment up to  $1^{7}/8$ ".

Ordering: Specify nominal tube size, figure number, name and finish






FIG. CT-65: LOADS (LBS) • WEIGHT (LBS) • DIMENSIONS (IN)									
Tube Size	Max Load	Weight	Rod Size A	В	С	D	Rod Take Out - E	Adjustment F	
1/2	150	0.09	3/6	1½	127/32	1 <sup>7</sup> /16	11/16	5/16	
3/4		0.10		111/16	23/32	19/16	11/4	7/16	
1	250	0.17		11/6	213/32	1%	17/16	1/2	
11/4		0.18		<b>2</b> 5⁄32	213/16	13/4	111/16	5∕8	
11/2		0.21		217/32	3¾	1 15/16	21/16	13/16	
2		0.26		311/32	417/32	25/16	21/8	13/16	
21/2	350 0.48 0.55 400 0.60	0.48		3 <sup>27</sup> /s <sub>2</sub>	5%32	2¾	31/4	15/16	
3		0.55		415/32	67/32	. 3	31/8	15/8	
4		]	431/32	631/32	31/4	4¾	11/4		

Note: Reflects changes in rod diameter from previously published data per recent revisions in MSS-SP-58 & 69

PROJECT INFORMATION	APPROVAL STAMP			
Project:	Approved			
Address:	Approved as noted			
Contractor:	■ Not approved			
Engineer:	Remarks:			
Submittal Date:	· :			
Notes 1:				
Notes 2:				

Catalog PH-2008